



Ref. Certif. No.

FR_719297

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Transfer switching equipment
Transfer Switching Equipment (Class PC)

Name and address of the applicant

ZHEJIANG GEYA ELECTRICAL CO., LTD
WENZHOU BRIDGE INDUSTRIAL ZONE, BEIBAIXIANG TOWN
YUEQING, ZHEJIANG, 325603 - CHINA

Name and address of the manufacturer

ZHEJIANG GEYA ELECTRICAL CO., LTD
WENZHOU BRIDGE INDUSTRIAL ZONE, BEIBAIXIANG TOWN
YUEQING, ZHEJIANG, 325603 - CHINA

Name and address of the factory

ZHEJIANG GEYA ELECTRICAL CO., LTD
WENZHOU BRIDGE INDUSTRIAL ZONE, BEIBAIXIANG TOWN
YUEQING, ZHEJIANG, 325603 - CHINA

Note: When more than one factory, please report on page 2

☐ Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

G2R-63

Additional information (if necessary may also be reported on page 2)

☐ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60947-1:2020
IEC 60947-6-1:2021

As shown in the Test Report Ref. No. which forms part of this Certificate

24119Y90007

This CB Test Certificate is issued by the National Certification Body




LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 14/06/2024



LABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 363 174
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSES

Signature: 
Julien GAUTHIER
Certification Officer

ANNEX


References, ratings and main characteristics:

Class of equipment	PC
Method of controlling	ATSE
Number of poles	1P+N
Rated operational voltage Ue (V)	220VAC
Rated insulation voltage Ui (V)	690V
Rated impulse withstand voltage Uimp (kV)	8kV
Conventional free air thermal current Ith (A)	63A
Rated operational current Ie (A)	16A, 20A, 32A, 40A, 50A, 63A
Rated frequency (Hz)	50/60Hz
Utilization category	AC-31B
Rated short-time withstand current Icw (kA)	5kA/0,03s
Rated short-circuit making capacity Icm (kA)	7,65kA peak
EMC environment	Class A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 14/06/2024



Signature: **Julien GAUTHIER**
Certification Officer