

IEC

IECEE

Ref. Certif. No.

CN57793

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Current Relay

Name and address of the applicant

ZHEJIANG GEYA ELECTRICAL CO.,LTD
Wenzhou Bridge Industrial Zone, Beibaixiang Town, Yueqing,
Zhejiang, P.R.China

Name and address of the manufacturer

ZHEJIANG GEYA ELECTRICAL CO.,LTD
Wenzhou Bridge Industrial Zone, Beibaixiang Town, Yueqing,
Zhejiang, P.R.China

Name and address of the factory

ZHEJIANG GEYA ELECTRICAL CO.,LTD
Floor3-5, Building 5, No.91, Binjiang Road, Quantou Village,
Beibaixiang Town, Leqing City, Zhejiang Province

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Uimp:2.5kV;Ui:250V;Ue:250V;Ie:1.5A;Ith:8A;Utilization
Category:AC-15;IP20

Trademark / Brand (if any)

N/A

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

GRI8-06A,GRI8-06B;

Additional information (if necessary may also be
reported on page 2)A sample of the product was tested and found
to be in conformity with

IEC 60947-5-1:2016(4th Edition)

As shown in the Test Report Ref. No. which
forms part of this Certificate

(2022)FQIIDQ-0886

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Sep.08,2022

Signature:

谢肇煦

Xie ZhaoXu



CB 0068601