



Ref. Certif. No.

SE-91973**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME****CB TEST CERTIFICATE**

Product

Switch-disconnectors

Name and address of the applicant

Zhejiang GEYA Electrical Co., Ltd.
Wenzhou Bridge Industrial Zone, Beibaixiang Town,
Yueqing City, Zhejiang, P.R. China

Name and address of the manufacturer

Same as applicant

Name and address of the factory

Note: When more than one factory, please report on page 2

Same as applicant

Ratings and principal characteristics

Ue= 240V~(1P), 415V~(2P, 3P, 4P)
Ie= 16, 20, 25, 32, 40, 50, 63, 80, 100, 125A
Icw= 1500A/1s, Icm=3000A, Ui= 500V, Uimp=6kV, Cat. AC-22A

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

GYH8

Additional information (if necessary may also be reported on page 2)

-

A sample of the product was tested and found to be in conformity with

IEC 60947-3:2008+A1

As shown in the Test Report Ref. No. which forms part of this Certificate

180702943SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Box 1103
SE-164 22 Kista, Sweden
Int +46 8 750 00 00

Date: 21 September 2018

intertek

Signature:

Fredrik Wennersten