

Test Verification of Conformity

Verification Number: 180702943SHA-V1

On the basis of the referenced test report(s), sample(s) tested of the below product have been found to comply with the standards harmonized with the directives listed on this verification at the time the tests were carried out. Other standards and Directives may be relevant to the product. This verification is part of the full test report(s) and should be read in conjunction with it <them>.

Once compliance with all product relevant **CE** mark directives are verified, including any relevant e.g. risk assessment and production control, the manufacturer may indicate compliance by signing a Declaration of Conformity themselves and applying the mark to products identical to the tested sample(s).

Applicant Name & Address:	Zhejiang GEYA Electrical Co.,Ltd Wenzhou Bridge Industrial Zone, Beibaixiang Town, Yueqing City, Zhejiang, P.R.China
Manufacturing Site Name & Address:	Same as applicant
Product Description:	Switch-disconnectors
Ratings & Principle Characteristics:	Ue= 240V~(1P), 415V~(2P, 3P, 4P) Ie= 16, 20, 25, 32, 40, 50, 63, 80, 100, 125A Icw= 1500A/1s, Icm=3000A, Ui= 500V, Uimp=6kV, Cat. AC-22A
Models/Type References:	GYH8
Brand Name(s):	
Standard(s)/Directive(s):	EN 60947-3: 2009 +A1:2012 +A2:2015 Low Voltage Directive 2014/35/EU
Verification Issuing Office Name & Address:	Intertek Testing Services Shanghai Building No.86, 1198 Qinzhou Road (North), Shanghai 200233, China
Test Report Number(s):	180702943SHA-001



Signature

Name: Oliver Wei

Position: Manager

Date: 28 September 2018