



BV LCIE
CHINA
Number

N° 2266AS10GYB47153

ATTESTATION of conformity with European Directives

Product: RCCB
Reference: GYL9
Issued to: ZHEJIANG GEYA ELECTRICAL CO., LTD.
Address: WENZHOU BRIDGE INDUSTRIAL ZONE, BEIBAIXIANG TOWN
325603 YUEQING, ZHEJIANG - CHINA
Manufacturer: ZHEJIANG GEYA ELECTRICAL CO., LTD.

Technical characteristics:
1P+N and 3P+N(neutral on left)
230/240V(1P+N);400/415V(3P+N)
In=16A; 25A; 40A; 63A; 80A
Inc=IΔc=10000A
Im=IΔm=500A for 16A; 25A; 40A and 10In for 63A; 80A
IΔn=30mA; 100mA; 300mA
Grid distance = 50mm
Ui= 415V
Uimp=4kV
Material group=IIIa
Screw diameter=5,9mm
50/60Hz

The submitted sample of the above equipment has been tested for **CE** marking according to following European Directive and following standards:

Low Voltage Directive 2014/35/EU

Standards	Report number	Report date
EN 61008-1:2012+A1:2014+A2:2014+A11:2015 +A12:2017 EN 61008-2-1:1994+A11:1998	B220097	18/10/2022

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product
The **CE** marking may be affixed if all relevant and effective European Directives with **CE** are applicable

Shanghai (P.R. China), October 19th, 2022.

Charlie CHEN
Product Line Manager



This document shall not be reproduced, except in full, without the written approval of BV LCIE China.
Information given in this document, are related to the tested specimen of the described electrical sample.

LCIE CHINA

必维欧亚电气技术咨询服务(上海)有
限公司

Building 4, No. 518, Xin Zhuan Road,
CaoHejing Songjiang High-Tech Park,
Shanghai P.R.C (201612)

Tel: +86 21 6195 7000
Fax: +86 21 6195 7001
Email: contact@cn.bureauveritas.com