



BV LCIE
CHINA
Number

N° 1966AS10GYB33100

ATTESTATION of conformity with European Directives

Product: MCB
Reference: GYM8 Series
Issued to: ZHEJIANG GEYA ELECTRICAL CO., LTD
Address: WENZHOU BRIDGE INDUSTRIAL ZONE, BEIBAIXIANG TOWN
325603 YUEQING, ZHEJIANG- CHINA
Manufacturer: ZHEJIANG GEYA ELECTRICAL CO., LTD
Type B,C and D
Ue=220V/380V,230V/400V,240V/415V ~(1P);380V,400V,415V
~(2P;3P;4P)
In=1A;2A;3A;4A;5A;6A;10A;13A;15A;16A;20A;25A;32A;40A;50A;63A
Ics=Icn=Icn1=4500A and 3000A
Technical characteristics: Energy limit class: 1(Type B and C)
(according to EN 60898-1)
Grid distance: 35mm
Ui=500V
Uimp=4kV
Screw diameter of load terminal =4,9mm

The submitted sample of the above equipment has been tested for **CE** marking according to following European Directive and following standards:

Low Voltage Directive 2014/35/EU

Standards	Report number	Report date
EN 60898-1:2019	B190047	17/10/2019

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product
The **CE** marking may be affixed if all relevant and effective European Directives with **CE** are applicable

Shanghai (P.R. China), , October 25th, 2019.



Chao JI CHEN
Product Line Manager



This document shall not be reproduced, except in full, without the written approval of BV LCIE China.
Information given in this document, are related to the tested specimen of the described electrical sample.

LCIE CHINA
必维欧亚电气技术咨询服务(上海)有限公司
Version 3/2016.02.19

Building 4, No. 518, Xin Zhuan Road,
CaoHejing Songjiang High-Tech Park,
Shanghai P.R.C (201612)

Tel: +86 21 6195 7000
Fax: +86 21 6195 7001
Email: contact@cn.bureauveritas.com