



BV LCIE
CHINA
Number

N° 2266AS01GYB43919

ATTESTATION of conformity with European Directives

Product: MCB
Reference: GYM9H-DC
Issued to: ZHEJIANG GEYA ELECTRICAL CO., LTD
Address: Wenzhou Bridge Industrial Zone, Beibaixiang Twon, Yueqing City,
Zhejiang Province, China 325603
Manufacturer: ZHEJIANG GEYA ELECTRICAL CO., LTD
Ue: DC220V(1P);DC440V(2P)
Utilization category: A
Ie:6A; 10A; 16A; 20A; 25A; 32A; 40A; 50A; 63A
Ics=Icu=6kA
Ui= 440V
Technical characteristics: Uimp=4kV
IP20 for front cover
Pollution degree: 2
Reference temperature: 30°C
Distance for metal screen:
Back:0mm Front:0mm; Top:50mm Bottom:50mm; Left:0mm
Right:0mm(values declared by client)

The submitted sample of the above equipment has been tested for **CE** marking according to following European Directive and following standards:

Low Voltage Directive 2014/35/EU

Standards	Report number	Report date
EN 60947-2:2017+A1:2020 EN 60947-1:2007 + A1:2011 + A2:2014	2111990014	18/12/2022

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product
The **CE** marking may be affixed if all relevant and effective European Directives with **CE** are applicable

Shanghai (P.R. China), January 6th, 2022.

Charlie CHEN
Product Line Manager



This document shall not be reproduced, except in full, without the written approval of BV LCIE China.
Information given in this document, are related to the tested specimen of the described electrical sample.

LCIE CHINA

必维欧亚电气技术咨询服务(上海)有
限公司

Building 4, No. 518, Xin Zhuan Road,
CaoHejing Songjiang High-Tech Park,
Shanghai P.R.C (201612)

Tel: +86 21 6195 7000
Fax: +86 21 6195 7001
Email: contact@cn.bureauveritas.com