

VERIFICATION OF LVD COMPLIANCE

Applicant: ZHEJIANG GEYA ELECTRICAL CO.,LTD
Wenzhou Bridge Industrial Zone, Beibaixiang Town, Yueqing, Zhejiang, China

Manufacturer: The same as applicant

Product Description: Conventional circuit-breaker

Model No: GYW1-6300, GYW1-3200, GYW1-3200/4

Rating: GYW1-6300;Uimp:12kV;Ue:AC400/690V;Ui:1000V;Rated frequency:50Hz;In:4000A、5000A、6300A;AC400V:Ics:138kA, Icu:138kA, Icw:138kA/1s;AC690V:Ics:105kA, Icu:105kA, Icw:105kA/1s; 3P, 4P; GYW1-3200, GYW1-3200/4; Ui:1000V;Uimp:12kV;Ue:AC400/690V;Rated frequency:50Hz;In:2000A、2500A、2900A、3200A (3P、4P), 3600A、4000A (3P);AC400V:Ics:65kA, Icu:100kA, Icw:65kA/1s;AC690V:Ics:50kA, Icu:65kA, Icw:50kA/1s; 3P, 4P

Sufficient samples of the product have been tested and found to be in conformity with

Test Standard: EN 60947-2:2006+A2:2013

As shown in the

Test Report Number(s): TLZJ19052318248

Date of issue: Jun. 04, 2019


Date of Expiry: Jun. 03, 2024

Conclusion

This Verification of LVD Compliance has been granted to the applicant based on the results of the tests, performed by laboratory of Global Testing Services Co., Ltd on the sample of the above-mentioned product in accordance with the provisions of the relevant specific standards and the Directive 2014/35/EU. The CE mark as shown below can be used, under the responsibility of the manufacturer, after completion of an EU Declaration of Conformity and compliance with all relevant EU Directives. The affixing of the CE marking presumes in addition that the conditions in annexes III and V of the Directive are fulfilled.

Approved by: Hermann Weiher

For and on behalf of
Global Testing Services Co., Ltd



Global Testing Services Co., Ltd

E-mail: info@gts-lab.com <http://www.gts-lab.com>

Floor 2nd, Building D-1, No. 128, Shenfu Road, Minhang District, Shanghai, China.

Copyright of this certificate is owned by Global Testing Services Co., Ltd and may not be reproduced other than in full and with the prior approval of the General Manager.